

Certificate of Approval

This certificate confirms that the company below complies with the following standard(s):

Company Name	Fire Safety Equipment Pty Ltd	Client ID	103334
Company Other Name	The trustee for Mergard & Morris Trust	Type of Certification	Product Certification; System 5
Certification Standard	AS/NZS 1841.4-2007 : Portable fire extinguishers - Specific requirements for foam type extinguishers		
Scheme	Global-Mark Product Conformance Scheme		
Certification Review Date	9/04/2017	Certification Expiry Date	4/02/2023
Certificate Issue Date	18/04/2017	Certificate Last Update Date	18/04/2018

APPROVED COMPANY/SITE ADDRESS(ES):

**2A Staple Street Seventeen Mile Rocks 4073 QLD Australia
Wucheyan Huangjiang Town Yuyao - Zhejiang China**

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager



Unique Certificate Code: **2927C09A6232E239CA2582720002D198**

Global-Mark Pty Ltd, 407, 32 Delhi Road, North Ryde NSW 2113, Australia - Copyright 2005



Global-Mark.com.au®





global-mark®

Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:

In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the expertise of external bodies (laboratories, and technical experts).

Model Identification	Model Name	Brand Name	Product Description/Attributes	Date Approved
302	3.0 L Foam type extinguisher	Various	3.0 L AFFF foam, Rating: 2A:5B:2F, FERN: 3334.4-02	21/07/2009
902	9.0 L Foam type extinguisher	Fire Safety Service, NZ	9.0 L AFFF foam, Rating: 3A:20B, FERN: 3334.4-03	21/07/2009
E212	2.1 L Foam type extinguisher	Fire Safety Service, NZ	2.1 L AFFF foam, Rating: 1A:5B:1F, FERN: 3334.4-01	21/07/2009

Comments:

Construction of extinguisher complies with standard AS/NZS1841.1:2007 Portable fire extinguishers Part 1: General requirements.

End of the document



Certification Manager